


# Montana Association of Dam and Canal Systems

## *2024 Rock Lake Operator Repair and Monitoring System Improvements*

Karl Kingery, P.E., CFM  
Water Resources Engineer



# Rock Lake




- Not High Hazard Dam located in Crazy Mountains.



# Unique Construction

- Dam Height = 10 feet, 487 AF
- Operating Pool Depth = 40 feet, 1454 AF




Additional  
Reservoir storage  
created in 1966 by  
tunneling/blasting  
through mountain



# 2022 Survey



- Survey Performed using Drone and Ortho-imagery.
- Survey Performed at Low Water Level.
- Survey Gave Accurate and Detailed Bathymetric Map
- Level of Accuracy = approx. +/- 0.5 feet.
- Control Point Set During Survey.
- Hydrometrics Used Survey to Develop Accurate Stage-Storage Curve.



# 2024 Failure

July 17, 2024

Existing Gearbox Failed During Initial Operation of the Year, with Full Reservoir Pool on Original Gate.



# 2024 Emergency Repair

Planning for Repair, Sourcing of Materials, Equipment, Mobilization to Site and Installation of Emergency Fix  
All **Performed in 6 Days**

Emergency Repair Completed on July 23, 2024

Previous site visits, & sourcing of “off-the shelf” equipment and materials was


**CRITICAL!!!!**



# 2024 Emergency Repair

## Biggest Unknowns Going into Emergency Repair

- Thread pitch, lead and spacing of original stem
  - Believed was 3 TPI, single lead
  - Brought 3TPI, 2.5 TPI, and smooth machined couplers
- Force needed to break free gate
  - Performed Force Calculations (Estimated at ~ 40,000-50,000 pounds of lifting force needed to break gate free), ~3,000-4,000 ft-lbs .
  - Brought TWO gearboxes that were big enough, and that were “on the shelf”
  - Designed and Fabricated a “yoke” to sit on top of the structure.
- Limited most unknowns by bringing in a “system” that was self contained and didn’t rely on existing components.
  - Finding a 3” stem was difficult.



## *Required Lifting Force*

To determine the lifting force required to open a gate, the following formula is used:

$$F = 62.4APf + W + w + dp$$

Where:

- $F$  = lifting force required in pounds
- $A$  = area of gate opening in square feet
- $P$  = effective head of water in feet
- $f$  = coefficient of friction
- $W$  = weight of gate slide in pounds
- $w$  = weight of stem in pounds
- $dp$  = downpull in pounds

# 2024 Emergency Repair

HERE IT COMES



AND



IT FITS!



# 2024 Emergency Repair

GEARBOX SETUP



GEARBOX CONFIGURATION



YOKE INSTALLATION

# 2024 Emergency Repair

EMERGENCY REPAIR COMPLETE WITH 2 DAYS OF ONSITE WORK




# 2024...2 months later

The Emergency Repair worked, but it did not address the primary causes of the gearbox failure...exposure of the gearbox to weather



# Sept/Oct 2024 Improvement Objectives

- Install Permanent Structure Over Gearbox
- Install Operation System to Operate Gate Remotely
- Install Telemetry and Monitoring System to Observe and Monitor Reservoir, System, & Weather Conditions
- Install Reservoir Level Monitoring System
- Install Outlet Flow Monitoring System
- Install Saddle Dike to Protect Structure
- Repair Existing Dam




# Mobilization / Demobilization






# Gatehouse


- Protects system from elements and vandalism.
- Houses controls, batteries, gearboxes, and other critical system components.



# Gatehouse Construction




# Gatehouse Construction




# Gatehouse Construction


## CONSTRUCTION PROBLEMS



## CONSTRUCTION SOLUTIONS



# Gatehouse Construction



# Gatehouse Construction



# Gatehouse Construction




# Gatehouse Construction

- Once we didn't have that "thing", and the "thing" couldn't wait.
  - The 3/4-inch anchor bolts and nuts we had brought for the ladder went missing somewhere (presumably flown out by accident).
  - So, anchor bolt epoxy and a welder did the trick.
  - The ladder was properly "tested" prior to being put into service.



# Gatehouse Construction

- Sometimes it was a tight fit.



# Saddle Dike

- Protects system from flood waters



# Dam Repair

- Concrete was deteriorating due to corrosive water
- Repaired cracks and installed epoxy cured cement coating to surface


Before






After





# Transducer




**1** **DETAIL**  
NTS  
LOWER TRANSDUCER HOUSING TERMINATION



# Transducer Protection



# Outlet Tunnel Monitoring





- Installation of a cutthroat flume was too expensive, so prepared custom outlet rating curve
- Avoided Changing Outlet Flow profile
- Supercritical flow conditions
- Measurements taken using a radar water level sensor
- Custom curve developed based on Stage-Volume-Inflow-Drawdown Calculation



# Outlet Rating Curve Development

- Custom curve developed based on Stage-Volume-Inflow-Drawdown Calculation
- Due to water rights consideration, development needed to occur during a significant rainstorm



# Controls Construction

- Bringing Pre-assembled Materials Significantly reduced onsite time and risk of missing parts...unlike those 5/8 inch SS anchor bolt nuts



# Controls

- Gate Operations can be performed both manually and remotely
- Gate Can be set to a position point, or set to a flow point

LOCAL-STOP-REMOTE Switch:	REMOTE
Gate Control Mode Selection:	GATE POSITION
Live Actuator Torque:	18.0 %
Gate Open Percentage:	0.0 %
Gate Open Percent SETPOINT:	0.0 %
Outlet Flow Rate:	0.03 CFS
Outlet Flow Rate SETPOINT:	0.00 CFS
Outlet Flow Rate DEADBAND:	0.25 CFS

**GATE IN SERVICE**

**ROTORK CONTROL ALLOWED**

**GATE FULLY CLOSED**

**GATE FULLY OPEN**

**GATE OBSTRUCTED**

**GATE JAMMED**

**ROTORK GENERAL ALARM**

**ROTORK COMM FAIL**

### Flow Control Tuning

Outlet Flow Rate Deadband CFS: 0.25 CFS    Flow Within Deadband: ●

PID Loop Time: 300 Sec    Timer: 94 Sec    Remaining: 206 Sec


#### PID Control Tuning

PID STATUS	INACTIVE	
PID P-Value	-1.131	USE P-Output
PID P-Factor	0.200	ON OFF
PID P-Output	-0.226	
PID I-Value	0.000	USE I-Output
PID I-Factor	0.050	ON OFF
PID Maximum I-Value	10.0	
PID I-Output	0.000	
PID D-Value	0.000	USE D-Output
PID D-Factor	0.200	ON OFF
PID D-Output	0.000	
Gate Target Adjustment	-0.226 %	





# Controls

- Complex Wiring is simplified by separating out components into different circuits that can be turned off and on as needed.
- All circuits are monitored and controlled by the central datalogger/controller.




# Weather Monitoring

- Anemometer
  - 117 mph max wind recorded
- Rain Gauge
- Camera



Rainfall Rate: 0.00 In/Hr    Total Rainfall: 14.27 In

Amb. Temp: 45.2 DegF    Yest Max: ?? DegF    Min: ?? DegF



# System Monitoring

- Active and Current Battery and Temperature Monitoring
- Power intervention Built into datalogger programming
- Cellular & Satellite Telemetry




## System Information 10/9/2025, 10:15:34 PM

Voltages		Temperatures	
Solar Panel Voltage	0.01 V	Outdoor	45.0 DegF
48V Battery Bank	50.92 V	Battery Box	43.8 DegF
24V DC-DC Power	-0.00 V	Indoor	52.0 DegF
12V DC-DC Power	13.67 V	Controller	53.9 DegF

Battery Heater ON Threshold	15.0 DegF	<input type="checkbox"/>
Battery Heater OFF Threshold	25.0 DegF	<input type="checkbox"/>
Load Shedding Trig. Voltage	46.0 V	<input type="checkbox"/>
Load Shedding Hold-Off Time	120 Sec	<input type="checkbox"/>
Winter Auto Power-Down Time	3,600 Sec	<input type="checkbox"/>
Power-Down Countdown	3,600 Sec	<input type="button" value="Reset"/>



# QUESTIONS?



## Contact Information

[kkingery@hydrometrics.com](mailto:kkingery@hydrometrics.com)

**Hydrometrics, Inc.**  
Consulting Scientists and Engineers

3020 Bozeman Avenue, Helena, MT 59601 | (406) 443-4150